



**DEPARTMENT OF
PUBLIC WORKS**

ENGINEERING DIVISION

70 TAPLEY STREET
SPRINGFIELD, MA 01104

413-787-6210 413-787-6029 FAX



CITY OF SPRINGFIELD
MASSACHUSETTS

June 1, 2015

Mr. Timothy J. Williams, P.E.
Allen & Major Associates, Inc.
100 Commerce Way
P.O. Box 2118
Woburn, MA 01888-0118

Re: Springfield Rescue Mission
10 Mill St., Springfield, MA

Dear Mr. William

The Department of Public Works is in receipt of your re-submission of plans, narratives and responses to comments for the relocation of the Springfield Rescue Mission to 10 Mill St. in Springfield. New documentation submitted includes:

- Site Improvement Plans, 21 sheets, prepared by Allen & Major Associates, Inc., stamped, dated May 22, 2015.
- Copy of the Quitclaim Deed for the "Orr Realty Company" for the 10 Mil Street Property
- Traffic Impact Assessment dated May 26, 2015 prepared by TEC.

The Department of Public Works has reviewed your re-submission and we agree with all responses to comments and plan revisions submitted to the City. As part of our review however, we offer the following conditions of approval:

1. General

- The originally submitted drainage report for this project has been approved. Please submit a copy of the report with an engineer's stamp for our record.

2. Drawing C-1 Layout and Materials Plan

- Original Comment: *Given the driveway entrance widening that is proposed along Main St., on street parking from the driveway to Mill St. should be eliminated. Also signage of the on street parking north on Main St will also have to be adjusted. Please add signage modifications to the plan and include them in a narrative with the traffic narrative as it will require approval from the Traffic Commission.*

Your response is acceptable, however, there is an existing traffic sign on a light pole on Mill ST. near its intersection with Main St. that should be removed.

- Original Comment: *Please add signage indicating that "No Left Turns for trucks" will be allowed from southbound Main St. into the driveway along Main St.*

The plans show that you have added the sign, but it has been added on the site itself---it should be installed on Main St. prohibiting left-hand turns onto the site from Main St---not left-turns off of the site. Please adjust location

At this time the site plan is **approved for construction** assuming compliance with the above conditions. Please be advised that any changes to the approved site plans requires resubmission to the DPW for approval. Please be advised that you must also comply with the requirements and conditions of the Site Plans as previously approved by the Planning Department.

Sincerely,



Christopher M. Cignoli, P.E.
Director
Department of Public Works
cc. Hector Velez